

Water Testing Results - Siletz Valley School

Maximum Contaminant Level (MCL) is 0.02 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
Annex Sink Drinking Fountain	1607219-001	7/9/2016	0.00585
Girls Locker Room Drinking Fountain	1607219-002	7/9/2016	ND
Upstairs High School West Drinking Fountain	1607219-003	7/9/2016	0.00242
Upstairs High School East Drinking Fountain	1607219-004	7/9/2016	0.00476
Elementary West Wing Drinking Fountain	1607219-005	7/9/2016	ND

ND = Non Detect - Lead level is below the set detection limits